

# Grayson Rural Electric Cooperative Corporation *100 B-00305*

109 Bagby Park • Grayson, KY 41143-1292  
Telephone 606-474-5136 • 1-800-562-3532 • Fax 606-474-5862

**RECEIVED**

**JUL 21 2008**

**PUBLIC SERVICE  
COMMISSION**

July 18, 2008

Stephanie L. Stumbo  
Executive Director  
Kentucky Public Service Commission  
211 Sower Blvd  
P O. Box 615  
Frankfort, Ky 40602-0615

RE. Request for Deviation from  
807 KAR 5.041, Section 15(3)

Dear Director Stumbo:

Grayson R.E.C.C. requests permission to deviate from 807 KAR 5.041, Section 15(3), Periodic Testing of Single Phase Meters. We use electromechanical and solid state meters with automated meter reading devices. Currently, we read our meters every three years, as approved by Kentucky PSC Case No 9970, dated September 11, 1987.

We are requesting that we be allowed to test meters every nine (9) years, instead of every eight (8) years in order to coordinate more efficiently with our three (3) year meter reading rotation program. The meters we use allow us to retrieve readings on a daily basis and we respond to any abnormalities. Moving to a nine year testing schedule will result in significant savings for labor, transportation and related expenses.

If appropriate, we would be happy to meet with you to discuss this matter, or to provide any additional information you may require. Questions can be directed to Randy Blevins, Manager of Power Use and Metering. Thank you for your consideration of this matter.

Sincerely,



Carol Hall Fraley  
President and CEO  
GRAYSON RURAL ELECTRIC  
COOPERATIVE

CHF